

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
EL 103 EXAM	1/16/2026 07:07	1/21/2026 16:48	70402426001	Lead	5.1	5	ug/L
EL 103 BATHROOM	1/16/2026 07:07	1/21/2026 16:49	70402426002	Lead	2.2	5	ug/L
EL112 CS	1/16/2026 07:00	1/21/2026 16:53	70402426003	Lead	2.4	5	ug/L
EL 112A CS	1/16/2026 07:00	1/21/2026 16:59	70402426004	Lead	97.0	5	ug/L
EL 113 CS	1/16/2026 07:05	1/21/2026 17:02	70402426005	Lead	3.2	5	ug/L
EL 113A CS	1/16/2026 07:02	1/21/2026 17:04	70402426006	Lead	5.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb